




**KERALA WATER AUTHORITY**  
**QUALITY CONTROL DISTRICT LAB KASARAGOD, VIDYANAGAR**  
**WATER ANALYSIS REPORT**

Tele phone No : 04994 255791  
email : qclabkasaragod@gmail.com

Report No - KWA/QA/R/06/311/J/303 (a)		24/06/2023			
Customer Name and Address		1. Date of receipt		:23/06/2023	
Saadiya English Medium School Saadabad , Deli Kalanad Post Kasaragod (Non - Domestic)		2. Sample Provided by		Customer (QUA_72330)	
		3. Sample Code		17/23 (66)	
		4. Source of Sample		Bore Well	
		5. Sample quantity		: 100ml	
		6. Test performing dates		From: 23/06/2023	
SI No	Characteristics	3. Sample Code	Test Method	Acceptable limits as per IS 10500-2012	Result
1	Total Coliforms	CFU /100 ml	IS 15185:2016; ISO 9308 - 1: 2014	Nil	Nil
2	E.Coli	CFU /100 ml	IS 15185:2016; ISO 9308 - 1: 2014	Nil	Nil

**Remarks:**

The results stated above related only to the sample(s) submitted for testing. This test certificate shall not be reproduced except in full without the written approval of the laboratory.

  
**Analysed By**  
**Bacteriologist**  
**Quality Manager**  
Quality Control District Lab  
Kerala Water Authority  
Vidyanagar, Kasaragod - 671123

\* End Of Report\*

KWA/QC/DL/KSD/R/17

Issue No: 02

Issue Date : 06.05.2022

Rev No: 001

Rev Date:  
06.05.2022

Page 2 of 2

**For Sa-adiya English Medium  
Residential Senior Secondary School**  
  
**Chairman/Manager**

  
**Principal**  
**PRINCIPAL**  
**SA-ADIYA-ENGLISH MEDIUM**  
**RESIDENTIAL SENIOR SECONDARY SCHOOL**